

CERTIFICATION
For
FC4 and FC5 FABRICATED STEEL COUPLINGS

This is to certify that FC4 and FC5 Fabricated Steel Couplings shall conform to AWWA Standard C219. The center sleeve will be constructed of carbon steel meeting ASTM A36 Standard, with a 36,000 psi minimum yield. The end rings shall be manufactured using AISI 1020 cold rolled or extruded carbon steel with a 40,000 psi minimum yield. Gaskets will be SBR extruded rubber per ASTM D2000, with heat bonded joints. Bolts and nuts are to be high strength low alloy steel, ASTM A242 or AWWA C111.

FC4 and FC5 Fabricated Steel Couplings are available for nominal pipe sizes 14" and larger.

The Ford Meter Box Company is registered by Underwriters Laboratories, Inc. to the International Standards Organization for the ISO 9001 standard for quality. This is one of the most comprehensive standards within the ISO series, which establishes a model for quality assurance in design/development, production, installation, customer service and satisfaction.

THE FORD METER BOX COMPANY, INC.



Zach Prater
Product Sales Manager
Pipe Products and Uni-Flange