

**CERTIFICATION**  
**For**  
**FORD FS313 STAINLESS STEEL SADDLE**  
**(FOR 4" - 12" NOMINAL PIPE SIZES)**

This is to certify that FS313 Style Saddles shall be 100% constructed of Grade 18-8, Type 304 Stainless Steel. The band shall be 6" wide for outlet sizes ½" – 1".

A Buna-N gasket, compounded for water service meeting ASTM D2000 80M4AA607, will be affixed to the underside of the saddle top in order to provide an adequate sealing surface.

All welds used in the construction of the saddle will conform to AWS Codes (American Welding Society) and will be fully chemically passivated in order to allow the stainless steel to return to its original corrosion resistant condition.

Ford 4" – 12" FS313 Saddles with ¾" and 1" taps, if properly installed and maintained under normal service conditions, can be rated at 250 psi or the pipe rating, whichever is lower.

THE FORD METER BOX COMPANY, INC



Zach Prater  
Product Sales Manager  
Pipe Products and Uni-Flange