



The Ford Meter Box Company, Inc.

775 Manchester Avenue • P.O. Box 443, Wabash, Indiana U.S.A. 46992-0433
Phone: 260-563-3171 • Fax: 800-826-3487 • Overseas Fax: 260-563-0167 • www.fordmeterbox.com

Project Name: _____ Contractor Name: _____

Location: _____

NO-LEAD BRASS CERTIFICATION

This is to certify that no-lead brass curb stops, corporation stops, service line valves and fittings, and other no-lead brass products, as manufactured by The Ford Meter Box Company, Inc., Wabash, Indiana, with an "NL" designation at the end of the catalog number shall contain no more than 0.25% lead by weight per United States Public Law 111-380. The brass alloy used for all surfaces coming in contact with potable water shall meet the requirements of UNS/CDA No. C89833 as listed in the ANSI/AWWA C800 Standard, and the products produced with this alloy shall meet NSF/ANSI Standard 61 and/or NSF/ANSI Standard 372 as applicable, complying with the Safe Drinking Water Act.

These products shall have the letters "NL" cast into the main body for proper identification.

Brass components that do not come in contact with potable water shall meet the requirements of AWWA Standard C800 (ASTM B62 and ASTM B584 using UNS/CDA No. C83600). Brass components such as Pack Joint, Grip Joint and Quick Joint nut compression fittings, including but not limited to, yoke lock nuts, meter swivel nuts, flare copper nuts, union nuts and some meter adapters (cast only in 85-5-5-5 brass - UNS/CDA No. C83600) that do not come in contact with potable water are not required to comply with the no-lead law. Brass saddles (in most states) are exempt from the no-lead requirements.

Parties responsible for monitoring and maintaining proper water system design must exercise full responsibility in understanding and upholding the full intent and scope of applicable lead laws.

In addition, all brass goods designed to hold internal water pressure shall be individually tested by the manufacturer as an integral part of the production process to ensure that they meet the pressure requirements established by AWWA Standard C800. This requirement shall apply to each individual product; "batch" testing is not allowed.

THE FORD METER BOX COMPANY, INC.

Todd Hodson
Marketing Manager